

**OFFICE OF THE DY. DIRECTOR OF FACTORIES & BOILERS,  
ANGUL DIVISION, NALCO NAGAR – 759145, Tele-Fax: 06764-220164**

\*\*\*\*\*

File No. 6 VI (C) Divn. 48/15/ Letter No. 34 /Dt. 08-01-16

To

M/s Annapurna Rice Mill,  
At- Karanda, Po- Badalu,  
Dist- Dhenkanal.

Sub: Issue of Certificate for Boiler No. OR-768.


Sir,

The certificate No. 03 dt. 08.01.2016 in respect of your Boiler in Form VI is enclosed herewith, the receipt of which may please be acknowledged.

The provisional order granted by the Asst. Director of Factories and Boilers, Dhenkanal please be surrendered to him under intimation to this office.


Yours faithfully

Encl: As above.

  
Dy. Director of Factories and Boilers  
Angul Division


Memo No. 35 /Dated 08-01-16 <sup>O/C</sup>

Copy forwarded to the Asst. Director of Factories and Boilers, Dhenkanal for favour of information with reference to his letter No. 1332 dt. 07.12.2015.

  
Dy. Director of Factories and Boilers  
Angul Division

Memo No. 36 /Dated 08-01-16

Copy with a copy of declaration in form-B, submitted to the Director of Factories and Boilers, Odisha, Bhubaneswar for favour of information & necessary action.

  
Dy. Director of Factories and Boilers  
Angul Division

Form III--Form No. 603-A

FORM VI

Counterfoil

No. 03/16

Registry Number of Boiler OR/768 Type of Boiler HMT

Boiler Rating 84

Place and year of manufacture Trichy, 2004

Maximum Continuous Evaporation 2520 kg/hr

Name of owner M/s Annapurna Rice Mill

Situation of Boiler At - Karanda, P.O. - Badalo  
Dist - Dharmapuri

Repairs /

Remarks /

Hydraulically Tested on 27.11.15 to 15.81 kg. per sq. centimeter

Maximum pressure permitted 10.54 kg. per square centimeter for the period from 27.11.2015 to 26.11.2016

The loading of the Double Post safety valve not to exceed ten decimal five four kg/cm<sup>2</sup>

The main steam pipe tested hydraulically to a pressure of — kg. per square centimeter last on —

Fee Rs. 340000 paid on 16.10.15 & 23.11.15

Dated at Nalco Nagar

This \_\_\_\_\_ day of \_\_\_\_\_ 19 \_\_\_\_\_

03/16  
By. Director of Factories  
and Boilers, Angul Divn.  
Nalconagar

M. K. S.  
07.12.2015  
(Inspector)